



INSTITUT PRO TESTOVÁNÍ A CERTIFIKACI, a. s.

třída Tomáše Bati 299, Louky, 763 02 Zlín, Czech Republic
TESTING LABORATORY - TESTING DIVISION

Issues

ATTEST

No. 472118404-01

on samples:

Calido S30 ball valves

(this product contains materials:

black EPDM sealing, white PTFE material and CW617N brass)

client:

Arka Sp. Z o.o.

Ul. Ogrodowa 5, 76-004 Sianów, Poland

VAT reg. No.: PL6692224025

Values obtained and the assessment of the technical parameters:

Evaluated technical parameters of the leaching tests from samples "Black EPDM sealing and white PTFE material" meet hygienic requirements of the article 3 paragraph 2 of the Decree of the Czech Health Ministry No. 409/2005 Coll. *Hygienic requirements for articles intended to come into contact with water and for the water treatment, as amended by the Decree of the Czech Health Ministry No. 446/2021 Coll., for articles intended into the long time contact with drinking water.*

Evaluated samples do not negatively influence the sensorial properties of the drinking water.

Complete assessment of raw materials as required by article 10 of the Decree of the Czech Health Ministry No. 409/2005 Coll., as amended, is not a part of this attest.

The evaluated sample of CW617N brass meets hygienic requirements of the article 9 paragraph (1) d) and (2) of the Decree of the Czech Health Ministry No. 409/2005 Coll. *Hygienic requirements for articles intended to come into contact with water and for the water treatment, as amended, for the products made of brass intended into the direct contact with drinking water.*

This Attest was issued on the basis of following document: ALTR No. 472118404-01 from January 27, 2025, issued by Institut pro testování a certifikaci, a.s. Zlín.

Issued on: January 27, 2025

Valid till: January 31, 2028



Dipl. Ing. Jiří Samsonek, Ph.D.
Head of the testing laboratory

Conditions for use of the Attest and associated information:

1. The Attest applies only to the sample tested by our laboratory.
2. The Attest remains in effect until production technology, initial materials and standards or corresponding regulations are changed; however, its validity will extend beyond the period of its effect.
3. If further requirements of national or EU legal regulations apply to the product, the Attest does not replace procedures and documents necessary for assessment of compliance with these regulations.